



Operations Memorandum

To: CVG Airlines and Tenants
Subject: NFPA 410 Requirements for Ramp Extinguishers
Date: August 15, 2018

Effective Immediately

REQUIREMENTS FOR RAMP EXTINGUISHERS AT GATES AND REMOTE PARKING

Please review NFPA 410 guidance summarized below regarding the requirement of wheeled ramp extinguishers at gates and remote parking locations. This guidance is in addition to extinguishers required by NFPA 409.

- Extinguishers shall be provided for aircraft maintenance operations in accordance with NFPA 10, as required by the AHJ for the following operations:
 - (1) Electrical maintenance
 - (2) Oxygen system
 - (3) Fuel transfer
 - (4) Air ventilation
 - (5) Fuel tank repair
 - (6) Pressure testing operations of aircraft fuel systems
 - (7) Aircraft cleaning, paint removal, or painting operations
 - (8) Welding operations
 - (9) Cleaning and refurbishing operations
 - (10) Ramp operations
- Ramp operations shall have at least one wheeled extinguisher having a minimum listed rating of 80-B provided at each gate or stand or at intervals of 200 ft along the length of aircraft ramps.

Note that this requirement includes aircraft receiving maintenance at remote parking locations. If you have any questions or concerns regarding this regulation, please contact Steve Listerman, Fire Chief via email (slisterman@cvgairport.com).